

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 26

Dated: 15/5/24

It is certified that an inspection team headed by Ram Sakal Paswan

(Name of Officers with designation) from Regional Research Unit, PHED

inspected the Gurukul Vidyalaya Jaxang, Baghat, Muz. Bihax

(Name & Address of the school) on 10:05:2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 59 dated 15-5-2024

of Regional Laboratory (PHED Lab) certified that the

Gurukul Vidyalaya (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

15.05.24
CHEMIST
R.W.T.L. MUZAFFARPUR

Jitendra Kumar
Chemist

Regional Research P.H.E.D

To
Gurukul Vidyalaya
Jaxang, Baghat, Muz.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PUBLIC HEALTH ENGINEERING DEPARTMENT
Regional Water Testing Laboratory
Drinking Water Quality Report

Month : May 2024

District Name : Muzaffarpur Sample Collected by Binod Kumar Jha, Gurukul Vidyalaya

Sl. No.	Block	Panchayat	Village	Habitation/ Ward	Location of Source	Tested Parameters											Remarks
						pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	
1	Gaighat	West Jarang	Jarang	Jarang W. No-13	Gurukul Vidyalaya	7.26	1.2	607	394	230	56	21.6	10	228	0.2	15	
Desirable Limit ** (IS 10500-2012)						6.5-8.5	1 NTU	—	500 mg/l	300 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	
Permissible Limit* in absence source (IS 10500-2012)						NR	5 NTU	—	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NT	400 mg/l	

Binod
CHEMIST
R.W.T.L. MUZAFFARPUR